

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7210-1297:102 Page 1 of 1

CATEGORY: Flame Detector

LISTEE: Fire Sentry Corp., 593 Apollo Street, Brea, CA 92621
Contact: *David Daniels (714) 671-1100 Fax (714) 671-5821

DESIGN: Models SS3-A, SS3-AN multi-spectrum and SS3-AB, SS3-ABN Ultraviolet (UV) flame detectors. Suitable for indoor use only. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 12 – 28 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number and FM label.

APPROVAL: Listed as flame detectors for use with separately listed compatible fire alarm control units.

*Rev. 06-16-2003



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 16, 2003**

*Listing Expires **June 30, 2004***

Authorized By: **DIANE K. AREND**, Senior Deputy
Program Manager